

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
 Pier 1
 San Francisco, CA 94111
 Phone: (415) 274-0526
 Attention: **Noel Aquino**
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	08
Received by:	Frank P.
Date Received:	7/24/24.
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent Response:	7/25/24

BIDDER'S QUESTION	
Company Name: <u>ANVIL BUILDERS INC.</u>	Date <u>7/24/2024</u>
Contact Name: <u>RICHARD ECKELS</u>	Tel: <u>415.481.1038</u>
Title: <u>SUPERINTENDENT/ESTIMATOR</u>	Fax: <u>415.285.5005</u>
<i>Check One Only (Use separate form for each specification and drawing question.)</i>	
<input type="checkbox"/> Spec. Section: _____	Paragraph(s): _____
<input checked="" type="checkbox"/> Drawing Sheet: <u>S-7 thru S-10</u>	Detail(s): _____
<i>Question:</i> On Sheet S-7 thru S-10 calls out for torque piers but it does show how many torque piers are required. Can the port verify how many torque piers are required.	

CITY'S REPLY	
<input checked="" type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.	
<i>Reply:</i> please see detail 1/S-6 Foundation plan.	
By: <u>Frank Piruzmand</u>	Bureau/Firm: <u>DPW</u> Date: <u>7/24/24</u>

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.