

**SECTION 00 21 14**

**QUESTION ON BID DOCUMENTS (QBD) FORM**

*Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.*

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS  
 Contract No. 2852  
 To: Port of San Francisco  
 Pier 1  
 San Francisco, CA 94111  
 Phone: (415) 274-0526  
 Attention: **Noel Aquino**  
 Email: constructionbids@sfport.com

City Use Only	
QBD No. 012	
Received by:	Noel A.
Date Received:	7/29/24
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent Response:	

BIDDER'S QUESTION			
Company Name:	JMB Construction, Inc.	Date	7/29/24
Contact Name:	Dana Wilkins	Tel:	650-267-5300
Title:	Estimator	Fax:	650-267-5302
<i>Check One Only (Use separate form for each specification and drawing question.)</i>			
<input type="checkbox"/> Spec. Section:		Paragraph(s):	
<input checked="" type="checkbox"/> Drawing Sheet:	S-2	Detail(s):	
<b>Question:</b> Note 8 under Structural Steel and Miscellaneous Iron states all steel shall be hot-dip galvanize. Please confirm that permanent sheet pile left in the ground will not require galvanizing.			

CITY'S REPLY		
<input type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.		
<b>Reply:</b> Permanent sheet piles shall be galvanized.		
By: FP	Bureau/Firm: DPW	Date: 7/30/24

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.