

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
 Pier 1
 San Francisco, CA 94111
 Phone: (415) 274-0526
 Attention: **Noel Aquino**
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	02
Received by:	Noel A.
Date Received:	7/24/24
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	7/31/24

BIDDER'S QUESTION			
Company Name:	<u>ANVIL BUILDERS INC.</u>	Date	<u>7/24/2024</u>
Contact Name:	<u>RICHARD ECKELS</u>	Tel:	<u>415.481.1038</u>
Title:	<u>SUPERINTENDENT/ESTIMATOR</u>	Fax:	<u>415.285.5005</u>
<i>Check One Only (Use separate form for each specification and drawing question.)</i>			
<input checked="" type="checkbox"/> Spec. Section:	<u>33 33 00 -3</u>	Paragraph(s):	<u>M</u>
<input checked="" type="checkbox"/> Drawing Sheet:	<u>H-10</u>	Detail(s):	<u>Plan D</u>
<i>Question:</i> Calls out Furnish and install high flow device. There are no top or invert elev. per drawing sheet H-7 shows CB 9 but it does not show the high flow device. Can the port revise the drawing showing top and invert elevations.			

CITY'S REPLY		
<input type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.		
<i>Reply:</i> Rim and invert elevation of high flow device assembly manhole will be added to drawing H-7 via addendum.		
By: Jose A. Flores	Bureau/Firm: SFPW/BOE	Date: 7/25/2024

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.