

**SECTION 00 21 14**

**QUESTION ON BID DOCUMENTS (QBD) FORM**

*Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.*

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco  
 Pier 1  
 San Francisco, CA 94111  
 Phone: (415) 274-0526  
 Attention: **Noel Aquino**  
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	010
Received by:	Noel A.
Date Received:	7/24/24
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent Response:	8/1/24

BIDDER'S QUESTION	
Company Name: <u>ANVIL BUILDERS INC.</u>	Date <u>7/24/2024</u>
Contact Name: <u>RICHARD ECKELS</u>	Tel: <u>415.481.1038</u>
Title: <u>SUPERINTENDENT/ESTIMATOR</u>	Fax: <u>415.285.5005</u>
<i>Check One Only (Use separate form for each specification and drawing question.)</i>	
<input checked="" type="checkbox"/> Spec. Section: <u>33 33 00 -3</u>	Paragraph(s): <u>2.01 L &amp; M</u>
<input type="checkbox"/> Drawing Sheet:	Detail(s):
<p><i>Question:</i> Question from Hydro International: . As I stated on the phone, it's not clear what they are needing here. First off, our Downstream Defender is not what we are using for full trash capture. We now use our First Defense unit (see attached sell sheet).                      I need to know what the treatment rates are and the peak flow rates in order to size it correctly.</p>	

Please get me that info or at least the EOR so I can contact them

CITY'S REPLY	
<input checked="" type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.	
<p><i>Reply:</i> Please see Note 4/H-10 for treatment rates. These are the Peak flow rates :                      Plan "C"/H-10: 10.6 (cfs)                      Plan "D"/H-10: 2.4 (cfs)                      Plan "E"/H-10: 17.0 (cfs)                      Plan "F"/H-10: 6.1 (cfs)                      The intent is to install SWRCB certified full trash capture units inside existing manhole structures for Plans "C"/H-10, "E" /H-10 and "F"/H-10. See Note 2/H-10 for full trash capture unit for Plan "D"/H-10.</p>	
By: Jose A. Flores	Bureau/Firm: SFPW//BOE
Date: 8/1/2024	

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.