

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
 Pier 1
 San Francisco, CA 94111
 Phone: (415) 274-0526
 Attention: **Noel Aquino**
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	013
Received by:	Noel A.
Date Received:	7/29/24
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	

BIDDER'S QUESTION			
Company Name:	JMB Construction, Inc.	Date	7/29/24
Contact Name:	Dana Wilkins	Tel:	650-267-5300
Title:	Estimator	Fax:	650-267-5302
<i>Check One Only (Use separate form for each specification and drawing question.)</i>			
<input checked="" type="checkbox"/> Spec. Section:	09 90 00 , 2.1	Paragraph(s):	
<input type="checkbox"/> Drawing Sheet:		Detail(s):	
Question: Coating table does not specifically indicate if submerged ductile iron will require coating. Please clarify if ductile iron pipe in the wet well and valve vaults will require coating.			

CITY'S REPLY		
<input type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.		
Reply: All ductile iron pipe will require coating. Revised specification section 09 90 00 to be issued in an addendum.		
By: Jonathan Chang	Bureau/Firm: DPW-BOE	Date: 8/1/2024

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.