

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
 Pier 1
 San Francisco, CA 94111
 Phone: (415) 274-0526
 Attention: **Noel Aquino**
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	017
Received by:	Noel A.
Date Received:	7/31/24
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	

BIDDER'S QUESTION	
Company Name: <u>NTK Construction Inc.</u>	Date <u>7/31/24</u>
Contact Name: <u>Adam Bigham</u>	Tel: <u>415 - 643 - 1900</u>
Title: <u>Estimator</u>	Fax: _____
<i>Check One Only (Use separate form for each specification and drawing question.)</i>	
<input checked="" type="checkbox"/> Spec. Section: <u>33 41 00.10</u>	Paragraph(s): <u>2.6C</u>
<input type="checkbox"/> Drawing Sheet:	Detail(s): _____
<p><i>Question:</i> The specification states "Gaskets shall be rubber 0-rings in accordance with ASTM A-361 specifications. Only manufacturer-recommended lubricants shall be used." However, after speaking with Rinker, a manufacturer of RCP, they cannot do wet cast double gasket rubber 0-rings on pipes less than 24". Rinker claims that no manufacturer will do this.</p> <p>Can this requirement of ASTM A-361 be waived for the 12" pipe because it is only applicable to 24" pipe and larger?</p>	

CITY'S REPLY	
<input checked="" type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.	
<p><i>Reply:</i> The ASTM A- 361 requirement waiver request will be addressed in revised Specification Section 33 41 00.10 via addendum to follow .</p>	
By: Jose A. Flores	Bureau/Firm: SFPW/BOE
Date: 8/2/2024	

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.