

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
 Pier 1
 San Francisco, CA 94111
 Phone: (415) 274-0526
 Attention: **Noel Aquino**
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	020
Received by:	Noel A.
Date Received:	8/5/24
Addendum Issued?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Date Sent Response:	

BIDDER'S QUESTION	
Company Name: <u>ANVIL BUILDERS INC.</u>	Date <u>8/2/2024</u>
Contact Name: <u>RICHARD ECKELS</u>	Tel: <u>415.481.1038</u>
Title: <u>SUPERINTENDENT/ESTIMATOR</u>	Fax: <u>415.285.5005</u>
<i>Check One Only (Use separate form for each specification and drawing question.)</i>	
<input type="checkbox"/> Spec. Section: _____	Paragraph(s): _____
<input checked="" type="checkbox"/> Drawing Sheet: <u>S-2</u>	Detail(s): _____
<p>Question: Response to the permanent sheet piles to be galvanized. When sheet are installed the galvanize will be damaged, is there a requirement to repair the galvanized sheets. if so could you please explain.</p>	

CITY'S REPLY	
<input checked="" type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.	
<p>Reply: 1)as noted on on 3/S-7 leaving the sheet piles in is as an option. 2)it is required to follow the detail on 3/S-7 and steel note 8/S-2. protect the steel from corrosion. 3)if the sheet piles are to remain then anti-corrosion is required because the high ground water level on site. 4) per sheet pile provider " Anti-corrosive coatings are a top protective solution. Coal tar epoxy coating, glass flake epoxy coating, duplex coating systems, and hot dip galvanization are all popular options to help prevent corrosion." 5)installation is means and method and contractor's workmanship and responsibility.</p>	
By: FP	Bureau/Firm: dpw Date: 8/5/24

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.