

**SECTION 00 21 14**

**QUESTION ON BID DOCUMENTS (QBD) FORM**

*Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.*

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco  
 Pier 1  
 San Francisco, CA 94111  
 Phone: (415) 274-0526  
 Attention: **Noel Aquino**  
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	030
Received by:	Noel A.
Date Received:	8/12/24
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	

BIDDER'S QUESTION			
Company Name:	<u>ANVIL BUILDERS INC.</u>	Date	<u>8/12/2024</u>
Contact Name:	<u>RICHARD ECKELS</u>	Tel:	<u>415.481.1038</u>
Title:	<u>SUPERINTENDENT/ESTIMATOR</u>	Fax:	<u>415.285.5005</u>
<i>Check One Only (Use separate form for each specification and drawing question.)</i>			
<input checked="" type="checkbox"/> Spec. Section:	<u>33 33 00 -3</u>	Paragraph(s):	<u>2.01 L &amp; M</u>
<input checked="" type="checkbox"/> Drawing Sheet:	<u>H-10</u>	Detail(s):	<u>C, E, F</u>
<p><i>Question:</i> Hydro International response for the Downstream Defenders to be installed in MH 13, 14 &amp; 15. Hydro International does not make the Downstream Defender anymore for a full trash capture. Hydro International now make the first Defense Units, per Hydro International these units are not inserts they are full on Manholes with the unit inside. This will require the existing manholes 13, 14 &amp; 15 to be completely removed in order to install the new first defense units. Please see attached the new first defense units PDF and advise.</p>			

CITY'S REPLY		
<input type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.		
<p><i>Reply:</i>  <a href="#">Plan "C"/H-10, Plan "E"/H-10 and Plan "F"/H-10 are being deleted from this Contract. Drawings to be updated and published in future addendum.</a></p>		
By: <u>Jose A. Flores</u>	Bureau/Firm: <u>SFPW/BOE</u>	Date: <u>8/15/2024</u>

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.