

SECTION 00 21 14

QUESTION ON BID DOCUMENTS (QBD) FORM

Potential Bidders must complete this QBD Form and submit to the address below no later than 3 business days before the bid opening date.

Project: AMADOR STREET INFRASTRUCTURE IMPROVEMENTS

Contract No. 2852

To: Port of San Francisco
 Pier 1
 San Francisco, CA 94111
 Phone: (415) 274-0526
 Attention: **Noel Aquino**
 Email: constructionbids@sfport.com

City Use Only	
QBD No.	036
Received by:	Noel A.
Date Received:	8/20/24
Addendum Issued?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Date Sent Response:	8/22/24

BIDDER'S QUESTION			
Company Name:	<u>Basset Engineering</u>	Date:	<u>8/20/24</u>
Contact Name:	<u>Shane McCarthy</u>	Tel:	<u>415-597-6690</u>
Title:	<u>RCP Pipe</u>	Fax:	<u></u>
<i>Check One Only (Use separate form for each specification and drawing question.)</i>			
<input type="checkbox"/> Spec. Section:	<u>33 33 00</u>	Paragraph(s):	<u>2.1</u>
<input type="checkbox"/> Drawing Sheet:	<u></u>	Detail(s):	<u></u>
<i>Question:</i>			
Spec calls for Spun pipe. According to suppliers, nobody in the country makes spun pipe anymore and no one makes wet cast 12" and 15". Please provide a product that can be made in America. Additionally the addendum is incorrect as it should be ASTM C361 not A361			

CITY'S REPLY		
<input type="checkbox"/> Mark this box if the QBD can be answered by Bidder's review of the documents. Reply with location(s) where the information can be obtained.		
<i>Reply:</i>		
Vertically cast/dry cast is acceptable. The ASTM discrepancy will be addressed in Specification Section 33 41 00.10_Reinforced Concrete Pipe via Addendum.		
By: Jose A. Flores	Bureau/Firm: SFPW//BOE	Date: 8/22/2024

The reply is an answer to a Bidder's question. The reply does not change the Bid Documents unless the information contained therein is issued in an Addendum. At the sole discretion of the City, the question and reply may be returned to the questioner and distributed to all bidding general contractors for informational purposes.