



Site-Walk

January 8, 2024

Contract 2861

Wharf J9 Replacement Project: Phase 1 Float & Gangway

Selected Questions and Responses from Walk

1. What are the restrictions on the red-tagged Wharf J9?
 - a. Currently, the Port has restricted access due to failed railing. The deck has a limit of 40 psf live load and no vehicles are permitted.
2. Is it possible for contractors to dock outside of the Wharf J9 area for storage?
 - a. Submit QBD.
3. Clarify requirements for bridge.
 - a. Driving equipment on bridge may be acceptable provided that the traffic can be allowed through and equipment does not exceed the posted bridge load limits:
 - i. 4 ton per axle
 - ii. 8 ton gross
4. When will information regarding the funding be provided.
 - a. Refer to the meeting notes from the Pre-bid meeting.
5. Will a survey be provided after dredging?
 - a. A survey after dredging is expected.